

Certificate



for European Product Safety

Reference No. 806786


Heating cable, self-regulating

Type designation	T2 Röd
Certificate holder	Tyco Thermal Controls Nordic AB Flöjelbergsgatan 20B 431 37 Mölndal SWEDEN
The product complies with the standard(s)	SS 424 24 11:1992
Date of expiry	3 November 2009
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed



Niklas Larsson

Date 28 May 2008
Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.





Appendix

Reference No. 806786

Technical data


Type designation	T2 Röd
Rated voltage (V)	230
Number of conductors	2
Conductor resistance	15W/m
Product information	Reference according to SS 424 24 11: 90CM; IEC 60800: class C.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

This certificate replaces previously issued ref. No. 413587 dated 3 November 2004.
A new certificate has been issued on account of additional test according IEC 60800.

Manufacturing site(s) Tyco Thermal Controls LLC
2555 Bay Road
Redwood City, CA 94063
UNITED STATES

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed 
Niklas Larsson Date 28 May 2008

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

